

EVACUATOR

Site Alarms

Evacuator Synergy Text Master Module

The Evacuator Synergy Text Master module has been designed to transmit a text message to mobile telephone handsets warning the user that their Evacuator system is in Alarm (up to 5 mobile handsets)

Extensive testing of the unit has been carried out using O2 and Vodaphone networks only. These two service providers are only recommended by Evacuator Alarms. **Please beware of pay as you go SIM cards as these require regular top ups to remain active. Problems have been identified using Orange SIM cards with this product.**

Only use standard (large sized none push out 3 volt SIM cards) ensuring that it's not PIN code protected.

Always insert SIM before powering the unit up.

Programming of you GSM unit at point of manufacture is highly recommended. This will ensure that test signals and relay operations are configured correctly.

PLEASE NOTE:

On - Site Remote programming is possible but not recommended.

On - Site programming does not enable us to test the unit before use.

If you would like your unit programmed and tested before dispatch please complete the boxes below:

Programming is subject to our standard terms and conditions copy available upon request.

Date:	GSM SIM No:
Customer Name:	Evacuator office use only.
Customer Address:	Programmed By:
	Tested By:
Site Name (up to 15 Characters no spaces)	
Mobile phone number 1:	
Mobile phone number 2:	
Mobile phone number 3:	
Mobile phone number 4:	
Mobile phone number 5:	
Confirmed By:	
Sign:	Print: